CETEC
Professional Scientific Solutions

Fire Test Certificate

Friday April 17th, 2015

Supplier: Floortex (8 Whiteside Road, Clayton South, VIC 3169)

Sample Description: OZ Floor Oak Collection

Date Tested: March 2015 (Tested through FORAY Laboratories – NATA Accreditation 1231)

Test Method: ASISO 9239-1:2003 Reaction to Fire Tests for Floorings. Determination of the Burning Behaviour using a Radiant Heat Source.

Test Data:

ASISO 9239-1:2003	OZ FLOOR
Critical Heat Flux/Critical Radiant Flux*	5.0 kW/m^2
Smoke Value*	11 %.min
Penetration of flame through to substrate	Yes
Glowing	Yes
Smoldering	Yes

*Three test average value

Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant

Nick Joy
BSc(Hons)
Consultant

CV150326

CETEC Pty Ltd ABN 44 006 873 687 W: www.cetec.com.au
2/27 Normanby Rd, Notting Hill, VIC 3168 Australia - T: +613 9544 9111 - F: +613 9544 9122 - E: info@cetec.com.au
1/65 Nicholson St, St Leonards, NSW 2065 - T: +612 9966 9211 - F: +612 9966 9210 - E: sydney@cetec.com.au
Unit 2B, 121 Newmarket Rd Windsor, QLD 4030 – T: +617 3857 5531 – E: brisbane@cetec.com.au

OHS & Environmental Care
Sustainability
Advanced Laboratory/Analytical Services
Technology & Innovation