CETEC
Professional Scientific Solutions

OHS & Environmental Care
Sustainability
Advanced Laboratory/Analytical Services
Technology & Innovation

Emission Test Certificate

Friday, April 27th, 2018

Supplier: Floortex (8 Whiteside Road, Clayton South VIC 3169)

Sample Description: OZ Floors Oak-range

Date Tested: March 2018 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: ASTM D5116 "Standard Guide for Small-Scale Environmental Chamber Determinations of Organic Emissions from Indoor Material/Products".

Emission Data:

Green Building Council of Australia Green Star Office Design v3 IEQ-13	**OZ Floors Oak-Range**
Total Volatile Organic Compound Emission Rate limit <0.5mg/m^2/hr	Total Volatile Organic Compound Emission Rate: 0.008mg/m^2/hr
4-phenylcyclohexene Emission Rate limit <0.05mg/m^2/hr	4-phenylcyclohexene Emission Rate: <0.005mg/m^2/hr
Formaldehyde Emission Rate limit <0.1mg/m^2/hr	Formaldehyde Emission Rate: <0.007mg/m^2/hr

Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant

Nick Joy
BSc(Hons)
Consultant

CV150326